

Septic Inspection Preparation Checklist

Everything you need to do before, during, and after a professional septic inspection

- ✓ Pre-inspection preparation checklist (14 items)
- ✓ What to expect during each inspection type
- ✓ Understanding your inspection report
- ✓ Post-inspection maintenance plan and warning signs

Pre-Inspection Preparation Checklist

Before Booking the Inspection

- ☐ Determine your system type (conventional gravity, ATU, mound, pressure distribution, or unknown)
- ☐ Locate the as-built drawing or system diagram (county health department has a copy if you don't)
- ☐ Note the last pumping date and the pumping company used
- ☐ Check your county's approved inspector list (if applicable)
- ☐ For real estate: confirm whether your state requires a specific inspection protocol (Title 5, etc.)

1-2 Weeks Before the Inspection:

- ☐ Do NOT pump the tank before the inspection — the inspector needs to see operating levels
- ☐ Do NOT restrict water use — normal household water usage should continue
- ☐ Locate and mark the tank access point if you know where it is (flag or paint)
- ☐ Clear the area above and around the septic tank (move vehicles, debris, garden items)
- ☐ Clear access path from driveway to tank area for the pumping truck (12-foot wide minimum)
- ☐ Locate and mark the drain field area if known
- ☐ Mow the grass over the drain field area short for visual inspection

Day of Inspection

- ☐ Ensure all sinks, toilets, and showers are functional (inspector will run water)
- ☐ Make the nearest bathroom accessible for flow testing
- ☐ Have your system records available (as-built drawings, pumping history, repair records)
- ☐ Plan for the inspection to take 2-4 hours (you should be present)

Critical: Do NOT pump the tank before the inspection.

While it might seem helpful, an empty tank prevents the inspector from evaluating operating levels, flow rates, and whether the drain field is accepting effluent. Wait at least 2 weeks after any pumping before scheduling an inspection.

What to Expect During a Full Inspection

The Inspection Process — Step by Step

Step-by-step visual

- 1 Records review (10-15 min):** Inspector reviews as-built drawings, pumping history, and any known issues. Asks about household size, water usage, and system history.
- 2 Tank location and access (15-30 min):** If tank location is unknown, inspector uses probing rod or electronic locator. Lids uncovered and opened. If buried, digging required (expect \$50-\$250 extra).
- 3 Tank inspection (20-30 min):** Inspector measures sludge and scum levels, evaluates baffles (inlet and outlet), checks tank walls for cracks or deterioration, and inspects risers/lids.
- 4 Pumping (30-45 min):** Tank is pumped to evaluate condition of the tank floor, check for cracks or damage visible only when empty, and verify structural integrity. Tank is then observed as it refills.
- 5 Drain field evaluation (30-60 min):** Inspector probes the drain field area for saturation, checks for surface breakout (sewage surfacing), and evaluates vegetation patterns (lush green stripes indicate potential problems).
- 6 Flow test (15-30 min):** Water is run into the system to observe how it moves from tank to drain field. Verifies the system is accepting and dispersing effluent properly.
- 7 Distribution box check (if applicable, 15 min):** For systems with D-boxes, inspector opens and evaluates even distribution across drain field lines.
- 8 Report preparation (delivered within 24-72 hours):** Written report with findings, measurements, photos, pass/fail determination (for real estate), and maintenance recommendations.

Total time on-site

2-4 hours for a full inspection with pumping. Be present for the entire inspection — the inspector will walk you through findings in real-time and can answer questions about your specific system.

Understanding Your Inspection Report

How to Read Your Septic Inspection Report

Key measurements explained

Measurement	Healthy Range	Concern Level	Action Required
Sludge level	< 1/3 of tank depth	> 1/3 of tank depth	Pump soon; increase pump frequency
Scum layer	< 3 inches	> 6 inches	Pump needed; check for grease issues
Inlet baffle	Intact, clear	Damaged or missing	Repair/replace (\$150-\$400)
Outlet baffle	Intact, submerged 6-8"	Damaged, missing, or too high/low	Repair/replace (\$150-\$400); critical
Tank walls	Solid, no visible cracks	Hairline cracks or deterioration	Monitor; significant cracks = replacement
Drain field	Dry soil; no surface water	Saturated soil; standing water; odor	Major concern; may need replacement (\$5,000-\$30,000)
Distribution box	Even flow to all lines	Uneven distribution; tipped or damaged	Level/replace D-box (\$500-\$1,500)

Pass/Fail criteria

Status	What It Means	Impact on Transaction
Pass	System functioning as designed; meets code	Proceed with transaction
Conditional pass	Minor issues that need correction within specified timeframe	Negotiate repair credits or seller repair
Fail	System not functioning properly; does not meet code	Major negotiation point; repair or replace (\$5,000-\$50,000+)

A failed septic inspection during a real estate transaction does NOT mean the deal is dead.

It means the seller must address the issue. Common outcomes: seller repairs/replaces before closing, buyer receives a price credit, or the cost is escrowed at closing.

Warning Signs Your System Needs Attention

Don't Wait for the Inspection — Know These Warning Signs

Two-column layout with icons

URGENT — Call an Inspector Now

- Sewage odor inside the home or near the drain field
- Sewage surfacing in the yard (wet spots, standing water over drain field)
- Toilets and drains backing up into the house
- Gurgling sounds in plumbing when water is running
- Multiple slow drains throughout the house (not just one fixture)

SCHEDULE AN INSPECTION SOON

- Unusually green or lush grass over the drain field (in patches)
- Spongy or soggy ground over the drain field, especially when it hasn't rained
- Tank hasn't been pumped in 5+ years
- Increased water usage (new household members, addition of bathroom)
- Age of system exceeds 25 years
- Nearby well water test shows elevated bacteria

Your drain field is the expensive part.

Tank replacement costs \$3,000-\$7,000. Drain field replacement costs \$5,000-\$30,000. Most system failures are drain field failures caused by neglect (infrequent pumping), overloading (too much water), or damage (vehicles driving over the field).

Septic System Maintenance Schedule

Keep Your System Healthy — Maintenance Calendar

Annual/recurring tasks

Task	Frequency	Cost	Why It Matters
Professional pumping	Every 3-5 years	\$250-\$600	Prevents sludge from reaching drain field
Inspect baffles and tank	Every 3-5 years (with pumping)	Included with pump service	Catch damage early
Effluent filter cleaning	Every 6-12 months	DIY or \$50-\$100	Prevents solids from entering drain field
ATU maintenance (if applicable)	Per manufacturer schedule	\$100-\$300/visit	Required for proper operation; may be legally mandated
Full system inspection	Every 3-5 years	\$300-\$650	Comprehensive evaluation catches early problems
Drain field check (visual)	Monthly (DIY)	Free	Walk over drain field; check for wet spots, odor, unusual growth

Things that damage your septic system

DO	DON'T
Use water efficiently	Don't do all laundry in one day (space loads)
Use septic-safe toilet paper	Don't flush wipes (even "flushable" ones), feminine products, or grease
Divert roof drains away from drain field	Don't drive vehicles or park on drain field
Plant only grass over drain field	Don't plant trees/shrubs near tank or drain field (root intrusion)
Pump on schedule	Don't use garbage disposals (increases sludge by 50%)
Fix leaky faucets/toilets	Don't pour chemicals, paint, or solvents down drains

Cost of Neglect vs. Maintenance

Side-by-side comparison

Component	Maintained System	Neglected System
Pumping (every 3-5 years)	\$2,000-\$4,000	\$0 (skipped)
Routine inspections	\$1,000-\$2,000	\$0 (skipped)
Minor repairs (baffles, filters)	\$500-\$1,500	Not caught early
Drain field replacement	Usually not needed	\$10,000-\$30,000
Tank replacement	Usually not needed	\$3,000-\$7,000
Emergency repairs	Rare	\$2,000-\$5,000
Property value impact	Neutral or positive	-\$10,000 to -\$25,000
25-Year Total	\$3,500-\$7,500	\$15,000-\$67,000

Regular maintenance costs roughly \$150-\$300 per year.

A failed septic system costs \$15,000-\$50,000 to replace and can make a property unsellable. There is no home system where preventive maintenance has a higher ROI than septic.

SepticTrust

SepticTrust

1. ****Printability matters.**** Property owners and agents print these. Avoid large solid color areas on interior pages (waste ink). Reserve full-bleed backgrounds for cover and back cover only. 2. ****Tables are the star.**** These guides live or die on their reference tables. Make tables scannable, well-spaced, and easy to read at 100% zoom on screen AND when printed on letter paper. 3. ****Checklist pag**

Find inspectors at septictrust.com